


2ND FLOOR KEY PLAN

SCALE: NOT TO SCALE

BUSINESS

SEVENTH EDITION - FLORIDA FIRE PREVENTION CODE
NFPA 101 - TABLE 7.3.1.2 OCCUPANT LOAD FACTOR
2,645 SF @ 150 SF GROSS / OCCUP
18 OCCUPANTS




TYPE B - INFILL WALL

LIFE SAFETY PLAN

SCALE: 1/4" = 1'-0"

LEGEND

- WALL TYPE A-NEW WALL (SEE DETAIL)
- WALL TYPE B-1 HR RATED WALL (UL-419) AND (UL-V497)
- EXISTING WALLS - TO REMAIN
- EXISTING 1 HR RATED WALL (GA WP 1072)
- (1) 3'-0" WIDE EXIT DOOR = 180 OCCUPANCY
- TRAVEL DISTANCE = 000 FT
- BUSINESS - MAX. TRAVEL DISTANCE ALLOWED =300 FEET
- FE-SM — SURFACE MOUNT 2A: 10BC FIRE EXTINGUISHER
- FE-RC — SEMI RECESSED MOUNT 2A: 10BC FIRE EXTINGUISHER
- EXIT SIGNAGE / DIRECTION
- EM — EMERGENCY LIGHT
- EMERGENCY LIGHT / EXIT SIGN COMBINATION
- F — HORN / STROBE, WALL, CANDELA
- WALL TYPE
- FS — FIRE SUPPRESSION HEAD



WALL TYPE-B

SCALE: 3/8" = 1'-0" BASED ON UL-V497

JMDG ARCHITECTURE PLANNING + INTERIORS
633 TAMIAMI TRAIL N. SUITE 300
NAPLES, FL 34102
239 594 9778
www.jmdg-architecture.com

THE DRAWING INFORMATION AND DESIGN CONCEPT ON THIS PRINTED COPY OR ELECTRONIC FILE MEDIUM IS THE EXCLUSIVE COPYRIGHT PROTECTED PROPERTY AND CREATION OF JMDG ARCHITECTURE AND SHALL NOT BE REPRODUCED IN WHOLE OR IN PART WITHOUT THE EXPRESSED WRITTEN CONSENT OF JMDG ARCHITECTURE © 2025 JMDG ARCHITECTURE

PROJECT GLAMMERS

633 TAMIAMI TRAIL N. SUITE #201
NAPLES, FLORIDA

REVISIONS

NO.	DATE	DESCRIPTION

DRAWING SET

CONSTRUCTION DOCUMENTS
7/14/2026

PROJECT MANAGER: RTM
DRAWN / CHECKED GAB/ RTM

PROJECT NUMBER
26-42

SHEET TITLE
LIFE SAFETY PLAN

SHEET NUMBER
A1.0